



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, S0E

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Pobočka 0300 – Plzeň

CERTIFICATE

No. 030 – 057915

about the qualities of a product

Certified quality: Slipperiness according to the following test procedures:

DIN 51130:2014 Testing of floor coverings – Determination of the anti – slip properties – Workrooms and fields of activities with slip danger, walking method – Ramp test

P CEN/TS 16165:2013 Determination of slip resistance of pedestrian surfaces – Methods of evaluation

Product: Agglomerated stone TechniStone®

Producer: Technistone a.s., Bratři Štefanů 1070, 500 03 Hradec Králové

Order: Z 030190019

Achieved values:

Technistone designation	Working of the surface	DIN 51130, P CEN/TS 16165 (annex B) angle of slipperiness	DIN 51130, P CEN/TS 16165 (annex B) classification
Sand	Honed	12,0°	R10
	Matt	8,8°	R 9
Granit	Honed	10,2°	R 10
	Matt	8,3°	R 9
	Brushed	15,0°	R 10
	Antique	8,8°	R 9
Mirrors	Polish	7,0°	R 9
	Honed	13,0°	R 10
	Brushed	16,8°	R 10
Crystal	Polish	9,0°	R 9
	Honed	11,1°	R10
	Slate	17,1°	R10


The certificate is issued on the basis of the results of the tests stated in report no. 030-037525, 030-041192, 030-047811, 030-057914. The period of validity of the document shall be extended on the basis the expression of the producer (same technology of production).

Number of pages of certificate: 1

Certificate validity: till 31st January 2021

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 23rd January 2019



Ing. Alexander Trinner
Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 - Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic
☎: 377 243 331, ☎: 377 430 345, Fax: +420 377 430 347, Internat.: +420 377 244 158, ✉ e-mail: trinner@tzus.cz, www.tzus.cz
Banking details: KB Prague 1 Czech Republic, account number: 1501-931/0100 Co. Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679